

T E S T C E R T I F I C A T E

ST-25-08-18-01

Product: Laminate flooring: "Çamsan Original"
Thickness: 8,0 mm

Producer: Çamsan Ordu Ağaç Sanayi ve Ticaret Anonim Şirketi
Kökenli Mah. Sivas Yolu Çamsan Fırınlar Mücavir Sokak
No: 1 PK: 35
Altınordu / ORDU
Türkiye

Order: Determination of Laminate Flooring Topical Moisture Resistance
according to NALFA-Method

Test report: 2724320

Test results:


| Parameter | | Wet Swell (informative only) | Re-dry Swell / Rating | Requirements according NALFA |
|---------------------------------|--------------|---------------------------------|--------------------------|---------------------------------|
| Final Thickness Swell [mm] | Position 1 | 0,22 | 0,05 | Not applicable |
| | Position 2-4 | 0,12 | 0,02 | |
| Qualitative Rating Specimen 1/2 | | 2/2 | 1/1 | Fulfilled |
| Water Leakage | | Not detected | | Not applicable |

Dresden, 18/08/2025



Head of laboratory





Engineer in charge