

Report No/ Rapor No: 2025011307

Applicant/Deney Sahibi : ÇAMSAN ORDU AĞAÇ SANAYİ AŞ.
Applicant Address/ Adres: Mithatpaşa sok.No:32 Kanlıca -Beykoz/İst.

Contact Person / Yetkili : Semih MURATALDI
Contact Telephone / Telefon: 0452 225 53 00

Contact e-mail / E-Posta:

**Sample Accepted on** / Numune Tarihi : 18.12.2024 **Report Date** / Rapor Tarihi : 13.01.2025

**Total number of pages/**Rapor Sayfa: 3

Sample ID: Laminant Parke

	TEST/ INSPECTION	DIRECTIVE	METHOD	RESULT
*	Thermal Conductivity	The General Product Safety Directive (GPSD) (2001/95/EC)	EN 12664	0.1044 W/(m.K)

NOTE: This test/inspection result replaces the conformity assessment, can be presented to official institutions, and used in products and brochures.

ORATOR OF BUILDING

Seal Customer Representative

Laboratory Manager

Merve Nur KIRVELİ

K.rvefi

Merve ÖZLÜ

Test/inspection results, methods and other information about the sample shown in the relevant pages of this Report are based on the information specified in accordance with "Test/inspection Request Form (PR03-F01) conveyed to us from the Applicant. Test/inspection results are valid for the sample as identified above. Sample may not represent the lot which it belongs. This Report does not replace a Product Certificate. Full report or any part of it may not be reproduced or used for any other purpose without the written permission of EUROLAB Laboratory. Sampling has not been done by us. Unsigned and unsealed Reports are invalid. Analysis as indicated with "\*\*" are in the Scope of our Accreditation Certificate issued from UAF according to TS EN ISO/IEC 17020, 17025, Analysis as indicated with "\*\*" are performed at the external laboratories using accredited test/inspection methods according to EN ISO/IEC 17020, 17025 from UAF. Possible extra notes may add with starting N' to related pages. Tested and remaining samples will be keep in specified terms & conditions at test/inspection request and/or proposal form.Physically, chemically and microbiologically decomposed samples are discarded regardless of the storage period. Applicant can not claim any right in this regard. Results are shown in this Report on to include Measurement Uncertainty values are not taken in consideration during Pass/Fail assessment the of test/inspection results shown in this Report. Evaluation of the test/inspection report containing the inspection results, and when both the inspection certificate and inspection report are traceable to each other.

PR33-F01/08.10.2015/Rev:17.01.2017-R01



EN 12664: Thermal Performance Of Building Materials And Products- Determination Of Thermal Resistance By Means Of Guarded Hot Plate And Heat Flow Meter Methods — Dry And Moist Products Of Medium And Low Thermal Resistance

## Scope

This standard specifies principles and testing procedures for determining, by means of the guarded hot plate or heat flow meter methods, the thermal resistance of test specimens either in the dry state or conditioned to equilibrium with moist air, having a thermal resistance of not less than 0,1 m<sup>2</sup>·K/W and a thermal transmissivity or thermal conductivity up to 2,0 W/(m·K).

## **Guarded Hot Plate Method**

The heat flow through the material is measured by a centrally located heating plate.

During measurements, the perimeter of the plate is surrounded by a protective area, thus minimizing edge heat losses.

Double Specimen Configuration:In double specimen tests, the material is exposed to heat flow on two sides.

## **Test Result**

Test	Result	
Thermal Conductivity	0.1044 W/(m.K)	

## Sample Image



\*\*\*End Of Report\*\*\*

